



Product Service

# Compliance Document

No. D 073342 0262 Rev. 00

**Holder of Certificate:** **Sungrow Power Supply Co., Ltd.**  
No. 1699 Xiyou Road, New & High  
Technology Industrial Development Zone,  
230088 Hefei, Anhui  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Converter**  
**Grid-Connected Inverter**

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. See also notes overleaf.

**Test report no.:** 704091802547-00

**Date,** 2019-03-26

  
( Zhengdong Ma )

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD  
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

# Compliance Document

No. D 073342 0262 Rev. 00

Model(s): SG110CX

## Parameters:

Max. input voltage:	d.c. 1100 V
Min. MPP voltage:	d.c. 200 V
Max. MPP voltage:	d.c. 1000 V
Max. input current:	d.c. 9×26 A
Isc PV:	d.c. 9×40 A
Nominal grid voltage:	a.c. 3/N/PE ~, 400/230V
Nominal grid frequency:	50 Hz
Max. continuous output current:	a.c. 158.8 A
Rated output power:	100 kW
Max. apparent power:	110 kVA
Power factor range:	0.8Leading...0.8Lagging
Ambient temperature range:	-30°C...+60°C
Protective class:	I
Ingress protection:	IP66
Overvoltage category:	II(PV), III(Mains)

Tested according to:

- IEC 61683:1999
- EN 50530:2010/A1:2013
- IEC 60068-2-1:2007
- IEC 60068-2-2:2007
- IEC 60068-2-14:2009
- IEC 60068-2-30:2005
- IEC 60068-2-27:2008
- IEC 60068-2-64:2008

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證書 ◆ CERTIFICADO ◆ CERTIFICAT