



Attestation of Conformity

No. E8A 073342 0221 Rev. 00

Holder of Certificate: Sungrow Power Supply Co., Ltd.

No. 1699 Xiyou Road, New & High Technology Industrial Development Zone,

230088 Hefei, Anhui

PEOPLE'S REPUBLIC OF CHINA

Name of Object: Converter

PV Grid-connected Inverter

SG5KTL-MT, SG6KTL-MT, Model(s):

SG8KTL-M, SG10KTL-M, SG12KTL-M

Description of

Object:

Tested

Input voltage:

DC 200V~1100V

Max. input power:

5.5kW, 6.6kW,

8.8kW, 11kW, 13.2kW

Rated output voltage:

400VAC/3Ø

Rated frequency: Rated output power: 50Hz 5kW, 6kW,

8kW, 10kW, 12kW

Protection class:

EN 61000-6-2:2005

according to:

EN 61000-6-3:2007/A1:2011

IEC 61000-6-2:2005

IEC 61000-6-3:2006/A1:2010

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.:

4840918257000

Date,

2018-07-27

(Jun Bao)

After preparation of the necessary technical documentation as well as the EU Declaration of conformity the required CE marking can be affixed on the product. That Declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.