



VERIFICATION OF COMPLIANCE

No.:	SHES210500977302PVC
Applicant:	SUNGROW POWER SUPPLY CO., LTD. No.1699 Xiyou Rd., New & High Technology Industrial Development Zone Hefei, Anhui 230088, P. R. China
Product Description:	Grid-Connected PV Inverter
Model No.:	SG2.0RS-S; SG2.5RS-S; SG3.0RS-S; SG3.0RS; SG3.6RS; SG4.0RS; SG5.0RS; SG5.0RS-ADA; SG6.0RS; SG8.0RS; SG9.0RS; SG10RS
Rating:	Refer to page 2 and 3
Protection against Electric Shock:	Class I
Degree of Protection:	IP65
Additional Information (if any):	Single phase – Fixed installation
Sufficient samples of the product have been tested and found to be in conformity with	
Test Standard:	ENGINEERING RECOMMENDATION G99 ISSUE 1-AMENDMENT 6, 09 March 2020, REQUIREMENTS FOR THE CONNECTION OF GENERATION EQUIPMENT IN PARALLEL WITH PUBLIC DISTRIBUTION NETWORKS ON OR AFTER 27 APRIL 2019
as shown in the Test Report Number(s):	SHES210500977372

Van Hua
Laboratory Technical Manager
SGS-CSTC



2021-05-20

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

Note: You may contact us to validate this document by email address: EE.shanghai@sgs.com

Safety-VOC-F004
Rev01/Effective Date :2020-12-11
Page 1 of 3

This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf.
The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

SGSPAPER
20437864





VERIFICATION OF LVD COMPLIANCE

Attachment to Verification No. : SHES210500977302PVC

Rating:

Model	SG2.0RS-S	SG2.5RS-S	SG3.0RS-S	SG3.0RS	SG3.6RS	SG4.0RS
DC Input						
Max. DC voltage	600 V					
Start-up operating voltage	40 V					
MPPT voltage range	40~560V					
Max. input MPPT current	16A			16/16 A		
Max. input short circuit current	20 A			20/20 A		
AC Output						
Rated AC Output power (kW)	2000W	2500W	3000W	3000W	3680W	4000 W
Max. AC Output power (kVA)	2000VA	2500VA	3000VA	3000VA	3680VA	4000 VA
Max. output current	9.1A	11.4A	13.7A	13.7A	16A	18.2 A
Nominal grid voltage	230 V					
Nominal output frequency	50Hz					
Output power factor	> 0.99 (adjustable+/-0.8)					
Operating temperature range	-25 °C ~60 °C					
Ingress protection	IP65					
Protective class	Class I					

Van Hua
Laboratory Technical Manager
SGS-CSTC



2021-05-20

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

Note: You may contact us to validate this document by email address: EE.shanghai@sgs.com

Safety-VOC-F004
Rev01/Effective Date :2020-12-11
Page 2 of 3

This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf. The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

SGSPAPER
20437865





VERIFICATION OF LVD COMPLIANCE

Attachment to Verification No. : SHES210500977302PVC

Model	SG5.0RS	SG6.0RS	SG5.0RS-ADA	SG8.0RS	SG9.0RS	SG10RS
DC Input						
Max. DC voltage	600 V					
Start-up operating voltage	40 V					
MPPT voltage range	40~560V					
Max. input MPPT current	16/16 A		16/16/16 A			
Max. input short circuit current	20/20 A		20/20/20 A			
AC Output						
Rated AC Output power (kW)	5000 W	6000 W	5000 W	8000 W	9000 W	10000 W
Max. AC Output power (kVA)	5000 VA	6000 VA	5000 VA	8000 VA	9000 VA	10000 VA
Max. output current	22.8 A	27.3 A	22.8 A	36.4 A	41 A	45.5 A
Nominal grid voltage	230 V					
Nominal output frequency	50Hz					
Output power factor	> 0.99 (adjustable+/-0.8)					
Operating temperature range	-25 °C ~60 °C					
Ingress protection	IP65					
Protective class	Class I					

Van Hua
Laboratory Technical Manager
SGS-CSTC



2021-05-20

Copyright of this verification is owned by SGS-CSTC Standards Technical Services Co., Ltd. and may not be reproduced other than in full and with the prior approval of the General Manager. This verification is subjected to the governance of the General Conditions of Services, printed overleaf.

Member of SGS Group (Société Générale de Surveillance)

Note: You may contact us to validate this document by email address: EE.shanghai@sgs.com

Safety-VOC-F004
Rev01/Effective Date :2020-12-11
Page 3 of 3

This document is issued, on the Client's behalf, by the Company under its General Conditions of Service printed overleaf. The Client's attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.

Any other holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Clients instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.

SGSPAPER
20437879

